



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	12/19/08	Interpretation	08-034
Topic	Visible Notification Appliances		
Code Section(s)	2007 CBC 907.2.12, 907.9.1.1 2007 CFC 907.2.12, 907.10.1.1		
Requested by	Ernie Power Power Communication Systems, Inc. 4643-A Mission Gorge Place San Diego, CA 92120-4133 (619) 583-7400		

Are Visible Notification Appliances required in S-2 occupancy, enclosed parking areas of High-Rise Buildings?

Yes. All public use and common areas of a high-rise building which includes parking garages require audible and visible notification appliances installed in accordance with CFC and NFPA 72.